

C Series 220V Single Channel Temperature Transmitter

→ Introductions

This temperature transmitter converts the thermocouple/thermal resistance signals to current or voltage signals. The input, output, and power supply are galvanically isolated from each other.

The main advantages of the isolator are fast response, low dissipation and temperature stability. It can be interfaced with all kinds of device, such as DCS, PLC and other systems.

→ Parameters

Power supply: 85 V AC ~ 265 V AC (90 V DC ~ 360 V DC)

Input (1, 2, 3):

TC: K, E, S, B, J, T, R, N, WRe3 - WRe25, WRe5 - WRe26
2/3-wire RTD: Pt100, Cu100, Cu50, BA1, BA2

The input signal needs to be determined when ordering and can also be programmed. Other signal types is required special customization, please see the product label for details.

Line resistance: $\leq 20 \Omega$ per line

Output (7, 8, 9; 10, 11, 12):

Sink mode: 4 ~ 20 mA

Current: 0(4) ~ 20 mA; 0 ~ 10 mA

Voltage: 0(1) ~ 5 V; 0 ~ 10 V

Load resistance:

Sink mode: $R_L \leq [(U-3)/0.02] \Omega$; U: Loop power supply

0(4) ~ 20 mA: $\leq 550 \Omega$; 0 ~ 10 mA: $\leq 1.1 k\Omega$

0(1) ~ 5 V: $\geq 1 M\Omega$; 0 ~ 10 V: $\geq 2 M\Omega$

Transmission characteristics (25 °C $\pm$ 2 °C):

Response time: ≤ 0.5 s

Temperature drift: 30 ppm/°C

Cold junction compensation accuracy: ± 1 °C (Preheated for 10 minutes)

Cold junction compensation range: -20 °C ~ +60 °C

Electromagnetic compatibility: Accordance to IEC 61326-3-1

Dielectric strength (1 mA leakage current, 1 minute test time):

≥ 1500 V AC (Input /Output/Power supply)

Insulation resistance: $\geq 100 M\Omega$ (Input /Output/Power supply)

Ambient conditions:

Operation temperature: -20 °C ~ +60 °C

Relative humidity: 10% RH ~ 90% RH (40 °C)

Atmosphere pressure: 80 kPa ~ 106 kPa

Storage temperature: -40 °C ~ +80 °C

Power dissipation:

≤ 0.8 W (220 V AC, no-load)


≤ 1.2 W (220 V AC, full-load)

→ Model rules

NOTE : Output signal

→ Wiring diagram

Single input, double output




○ Follow mode: W


Nanjing New Power Electric Co., Ltd.

→ Installation

- The apparatus can be installed on the DIN 35 mm standard rail which is corresponding to DIN IEC 60715. The must be snapped onto the rail, and never slanted or tipped to the side.
- Installation and disassembly steps are shown in following figures:



A. Snap metal lock onto mounting rail, then rotate the device, as figure A, press down the device onto mounting rail.



B. Pry the metal lock off the rail with screwdriver as arrow shown, pull downward the springs, and rotate the device.

- C. Remove the device as arrow shows.
- As far as possible to mount it vertically, In order to dissipation the heat of the apparatus.

Vertically installation

induction from signal terminal and power supply, should conformity with the requirements on electromagnetic interference resistance of products in Class 3 industrial field atmosphere stipulated in IEC 61000-4; the atmosphere shall be free from gases that are corrosive to metal and plastic components.

- The apparatus must be installed, connected and adjusted by qualified personnel in non-hazardous area according with the instruction manual.
- The operator must strictly comply with the relevant local safety standards and guidelines.

→ Supplementary instructions

- Our company reserves the right to change the product information without prior notification to the user. If the contents of the description are different from website or sample, this description shall prevail.

→ Light indication

- **PWR**: Power indicator light shows green, it means work normally.
- **ALM**: Input signal state indicator (red), it is off during normal operation, remain bright when input over-range;
RTD: It is glitter when input line breakage or short circuit;
TC: It is glitter when input line breakage.

→ Attention

- The devices degree of protection is IP 20 and must be protected from undesirable ambient conditions (waterproofing, small foreign objects). It is suitable for installation in the control room or high density field cabinet, DIN 35 mm installation is convenient for installation and displacement.
- The devices were designed for use in pollution degree 2 and overvoltage category III as per IEC/EN 60664-1. If used in areas with higher pollution degree, the devices need to be protected accordingly.
- Installation position shall not be affected by strong mechanical vibration; impact and electromagnetic